

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3266-0450:108 Page 1 of 1

CATEGORY: Door Operators

LISTEE: LCN Closures, 121 West Railroad Ave., Princeton IL 61356
Contact: Ruth Gallianetti (815) 879-1355

DESIGN: Models *4610/4620 and *4630/4640 low energy pedestrian door operators. Units are fully automatic and are provided with a hydraulic door closer independent of motor and the electronic control. The operators are intended to be powered open only. In the event of the units being de-energized, the closer mechanism will bring the swinging door to the closed position. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120/220 VAC, 1.5 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door operators with remote switching for use to open doors. The closing force as measured at the latch side of the closing stile shall not exceed 40 lbs. Authority having jurisdiction should be consulted prior to installation.

*Rev 2-26-2003 JEK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 26, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager